



**HONEYWELL SILENT KNIGHT**

12 Clintonville Road  
Northford, CT 06472  
[www.silentknight.com](http://www.silentknight.com)

April 2024

**Honeywell Silent Knight 6000 Series Password Usability Improvement**

Please be advised that Honeywell Silent Knight firmware version 7.00.12, included with all 6000 Series addressable fire alarm control panels, includes the following improvement to password usability:

After initial power-up and login to the Admin1 user account, the default password must still be changed to a new, unique password. This new password must be 7-digits and cannot be sequential or easily guessed. However, once this password is changed, users will now have the option to store this same password to the following three profiles (resolving default password troubles for multiple user profiles with one menu option):

- Installer
- Multi-Site Installer
- Computer Access (uses first 6-digits only)

This firmware release also includes other bug fixes and performance improvements.

If you have any questions regarding this notice, please contact Silent Knight Technical Support at 1-800-446-6444 or [sk.technicalsupport@honeywell.com](mailto:sk.technicalsupport@honeywell.com)